



## **Annual Drinking Water Quality Report for 2022**

**Town of Jerusalem  
3816 Italy Hill Road  
Branchport, NY 14418  
Public Water Supply ID#NY6101266  
Keuka Park Consolidated Water District**

## *Introduction*

To comply with State regulations, the Penn Yan Municipal Utilities Board issues this annual report, which describes the quality of your drinking water. The purpose of this report is to provide you with an understanding of what is in your drinking water, create awareness of the need to protect our drinking water sources, and provide tips on how to conserve water. This report provides an overview of last year's water quality, including what your water contains and how it compares to State standards.

The Keuka Park Consolidated Water District, to comply with State regulations, is required to redistribute this Annual Water Quality Report to all Keuka Park Consolidated Water District bill paying customers. The quarterly service bill provides the direct link on the town website [www.jerusalem-ny.org](http://www.jerusalem-ny.org). If you would prefer to receive a paper copy, you may request one by email [kpsw@jerusalem-ny.org](mailto:kpsw@jerusalem-ny.org).

If you have any questions about this report or your drinking water in general, please contact Bradley Donovan, Water Operator in charge. If you want to learn more, you may attend any of the regularly schedule sewer and water committee meetings which are held at 3816 Italy Hill Road, Branchport, NY 14418 the Tuesday of each month. For more information, call the KPSW office at 315-595-6657 between 7:30 am to 3:30 pm Monday thru Friday. For the hearing impaired, the TDD number is 1-800-662-1220.

## *Where does my water come from?*

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals, and in some cases radioactive material and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants, inorganic contaminants, pesticides and herbicides, organic chemical contaminants, and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the Environmental Protection Agency (EPA) prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. State Health Department and Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. Our sole water source is Keuka Lake. During **2022**, our system did not experience any restriction of its water source. The water is pumped from the lake to the Water Treatment Plant located at 1515 West Lake Road. Matthew Fritz is the Chief Operator at the plant. After filtration, disinfection, fluoridation, and corrosion control treatment, the water is pumped to a two-million-gallon reservoir on the hill above the plant. The water then enters the distribution system by means of gravity.

## *Source Water Assessment Report*

A report was completed under the New York State Department of Health's Source Water Assessment Program (SWAP). The information contained in the report assists the State in overseeing public water systems and helps local authorities protect the quality of their source water. It is important to note that source water assessment reports estimate the potential for untreated drinking water sources to be impacted by contamination. These reports do not address the safety or quality of treated, finished, potable tap water.

## *Executive Summary - Water Assessment Report*

This assessment found an elevated susceptibility to contamination for this source of drinking water. The amount of agricultural lands in the assessment area results in elevated potential for phosphorus, DBP (disinfection by-products) precursor and pesticide contamination. While there are some facilities present, permitted discharges do not likely represent an important threat to source water quality based on their density in the assessment area. However, it appears that the total amount of wastewater discharged

to surface water in this assessment area is high enough to further raise the potential for contamination, particularly for protozoa. There is also noteworthy contamination susceptibility associated with other discrete contaminant sources and these facility types include CBS (Chemical Bulk Storage) and IHWS (Inactive Hazardous Waste Site).

## *Facts and Figures*

Our water treatment facility is a regional plant, owned by the Village of Penn Yan, which serves all **5,079** residents (2021 census), of Penn Yan through **2,335** service connections. In addition, approximately **3,000** residents of the Town of Jerusalem are served through connections at Indian Pines, West Lake Road, East Bluff Drive, Branchport, Guyanoga, and Keuka Park with a total of **1,152** service connections. Approximately **1,000** residents in the Town of Milo along East Lake Road are served through **365** service connections. There are approximately **700** residents in the Village of Dresden and along NYS Route 54 that are also served by the Water Treatment Plant through **242** service connections. The Town of Benton also draws water from Penn Yan Water Treatment plant; Benton currently distributes water to **999** of its residents through **363** connections. In the Town of Pulteney, **658** residents are being served through **424** service connections. The total amount of water produced in **2022** was **338,402,200** gallons. The amount of water delivered to all customers in **2022** was **310,097,082** gallons of which **175,497,844** gallons were sold to Village of Penn Yan accounts and **134,599,238** gallons to customers in the other municipalities. A total of **20,912,780** gallons were unavailable for resale, leaving an unaccounted total of **7,392,338** gallons, which was used to flush mains, fight fires, back wash the plant's filters, main breaks or was lost through leakage. The daily average amount of water produced per day in **2022** was **929,175** gallons. The highest single day of production in **2022** was **1,701,900** gallons.

The Town of Jerusalem purchased 54,919,867 gallons from Penn Yan during 2022. For the year 2022, Jerusalem billed a capital charge of \$188.21 per EDU, \$61.50 per quarter from January 1, 2022 to June 30, 2022 and \$85.00 per quarter from July 1, 2022 to December 31, 2022. The water rates are based on 10,000 gallons minimum.

The other villages and townships served by the Village's water treatment facility are charged a flat rate for water based on the cost of production and set their own rates for the water sold to their customers.

## *Are there contaminants in my drinking water?*

As the state regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, turbidity, inorganic compounds, nitrates, lead and copper, volatile organic compounds, total trihalomethanes, haloacetic acids, radiological and synthetic organic compounds. The following table depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. This is why some of our data – though representative – could be more than one year old. It should be noted that all drinking water, including bottled drinking water, could be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the drinking water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the New York State Department of Health's Geneva Office (315-789-3030).

## Table of Detected Contaminants

Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg.)	Unit of Measurement	MCLG	Reg. Limit (MCL, TT, or AL)	Likely Source of Contamination
<b>Inorganic Contaminants</b>							
<b>Fluoride</b>	No	12/20/22	0.52	ppm	N/A	2.2	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer
<b>Barium</b>	No	12/20/22	0.014	ppm	2	2	Discharge from drilling waste; discharge from metal refineries; erosion of natural deposits
<b>Nitrate</b>	No	5/04/22	0.21	ppm	--	10	Runoff from fertilizer use; leaching from septic tanks; sewage; erosion of natural deposits
<b>Copper (2)</b>	No	8/05/20	(range) 0.01- 0.15 (90 <sup>th</sup> Percentile) 0.11	ppm	--	1.3	Erosion of natural deposits; leaching; corrosion of household plumbing system; wood preservatives
<b>Lead (3)</b>	No	8/05/20	(range) ND -6.8  (90 <sup>th</sup> Percentile) 1.3	ppb	--	15	Erosion of natural deposits; corrosion of household plumbing systems
<b>Arsenic</b>	No	12/20/22	<0.001	ppm	--	0.01	Natural erosion; agriculture and manufacturing operation discharge; mostly from wood preservative chemicals
<b>Nickel</b>	No	12/20/22	<0.0005	ppm	--	0.1	The source is electroplated metal coatings; alkaline batteries; alloys like metal welding rods and solder
<b>Sodium</b>	No	12/20/22	19.2	ppm	N/A	See Health Effects	Naturally occurring; road salt; water softeners; animal waste

(2) The level presented represents the 90<sup>th</sup> percentile of the 30 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90<sup>th</sup> percentile is equal to or greater than 90% of the copper values detected at your water system. The action level for copper was not exceeded at any of the sites tested.

(3) The level presented represents the 90<sup>th</sup> percentile of the 30 samples collected. The action level for lead was not exceeded at any of the sites tested.

## Table of Detected Contaminants

Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg.)	Unit of Measurement	MCLG	Reg. Limit (MCL, TT, or AL)	Likely Source of Contamination
<b>Microbiological Contaminants</b>							
<b>Turbidity Filters highest Monthly Avg.</b>	No	8/2022	0.10	NTU	--	TT=95% of samples <0.3 NTU: this number is not to exceed 1 NTU	Soil runoff
<b>Turbidity Filters Single Highest Reading</b>	No	8/15/22	0.16	NTU	--	TT=95% of samples <0.3 NTU: this number is not to exceed 1 NTU	Soil runoff
<b>Turbidity Distribution system highest monthly avg.</b>	No	2/2022 4/2022	0.14 0.14	NTU	--	TT=<5 NTU	Distribution System

Note: Turbidity is a measure of the cloudiness of the water. We test it because it is a good indicator of the effectiveness of our filtration system. State regulations require that turbidity in the distribution system must always be below 5 NTU.

## Table of Detected Contaminants

Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg.)	Unit of Measurement	MCLG	Reg. Limit (MCL, TT, or AL)	Likely Source of Contamination
<b>Microbiological Contaminants</b>							
<b>Total Coliform</b>	No	Six samples per month	--	--	--	MCL=2 or more positive samples in one month	Naturally present in the environment
<b>Radiological Contaminants</b>							
<b>Gross Alpha activity (Including Radium – 226, but Excluding Radon and Uranium)</b>	No	7/10/19	<i>Gross Alpha</i> 0.136 + <i>Radium-226</i> 0.121  Total: 0.257	pCi/L	--	15 pCi/L	Erosion of Natural Deposits
<b>Radium-226</b>  <b>Radium-228</b>	No	7/10/19	<i>Radium-226</i> 0.121 + <i>Radium-228</i> 0.333  Total: 0.454	pCi/L	--	5 pCi/L	Erosion of Natural Deposits

## Table of Detected Contaminants

Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg.)	Unit of Measurement	MCLG	Reg. Limit (MCL, TT, or AL)	Likely Source of Contamination
<b>Disinfection By-Products Stage 2</b>							
<b>TTHM</b> (Total Trihalomethanes)	No	2/08/22 5/10/22 8/9/22 11/08/22	Max LRAA 59.0  Range of Results (37-72)	ppb	--	80	By-product of drinking water chlorination needed to kill harmful organisms. THMs are formed when source water contains large amounts of organic matter.
<b>HAA5s</b> (Halo Acetic Acids)	No	2/08/22 5/10/22 8/9/22 11/08/22	Max LRAA 22.25  Range of Results (8.3-30)	ppb	--	60	By-product of drinking water disinfection needed to kill harmful organisms

Note: This level represents the highest locational running annual average calculated quarterly from data collected.

### Definitions:

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

**Action Level (AL):** The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements, which a water system must follow.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Non-Detects (ND):** Laboratory analysis indicates that the constituent is not present.

**Nephelometric Turbidity Unit (NTU):** A measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

**Micrograms per liter (ug/L):** Corresponds to one part of liquid in one billion parts of liquid (parts per billion – ppb).

**Milligrams per liter (mg/L):** Corresponds to one part of liquid in one million parts of liquid (parts per million – ppm).

**ppb** – parts per billion & **ppm** – parts per million

## *What does this information mean?*

We have learned through our testing procedures that, while some contaminants have been detected, they were below the level allowed by State regulations. We have learned through our testing that some contaminants have been detected; however, the table(s) above, show that these contaminants were detected below the level allowed by the State.

## *Is the Water System Meeting Other Rules That Govern Operations?*

The Village of Penn Yan is required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During June 2022, we did not fully monitor or test for *Synthetic Organic Chemicals* and, therefore, cannot be sure of the quality of your drinking water at that time.

Throughout all of the other months, our system was in full compliance with applicable State drinking water operating, monitoring and reporting requirements.

The Town of Jerusalem did receive a violation of SSC Sections 5-1.50 and 5-1.72. Keuka Park Consolidated Water District is required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether your drinking water meets health standards. During December 2022, we did not fully monitor or test for coliform and therefore cannot be sure of the quality of your drinking water during that time.

Throughout all of the other months, our system was in full compliance with applicable State drinking water operating, monitoring and reporting requirements.

## *Information of Sodium*

Water containing more than 20mg/l of sodium should not be used for drinking by people on severely restricted sodium diets. Water containing more than 270mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

## *Information on Fluoride Addition*

Our System is one of the many water distribution systems in New York State that provides drinking water with a controlled, low level of fluoride for consumer dental health protection. According to the United States Centers for Disease Control, fluoride is very effective in preventing cavities when present in drinking water at an optimal range from 0.8 to 1.0 mg/l (parts per million). To ensure that the fluoride supplement in your water provides optimal dental protection, the State Department of Health requires that we monitor fluoride levels on a daily basis to make sure fluoride is maintained at a target level of **0.7 mg/l**. During **2022**, monitoring showed fluoride levels in your water were within 0.2 mg/l of the target level. None of the monitoring results showed fluoride at levels that approached the maximum limit of 2.2 mg/l MCL for fluoride.

## *Lead in Drinking Water*

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Keuka Park Consolidated Water District is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running the tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water

tested, contact The Town of Jerusalem – Keuka Park Consolidated Water District email: [kpsw@jerusalem-ny.org](mailto:kpsw@jerusalem-ny.org) or 315-595-6657. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

### *Do I Need to Take any Special Precautions?*

Although your drinking water meets or exceeds state and federal regulations, some people may be more vulnerable to disease-causing microorganisms or pathogens in drinking water than the general population. Persons with compromised immune systems, such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS, those with other immune system disorders, some elderly, and some infants can be at risk of infections. These people should seek advice from their health care provider(s) about their drinking water. EPA and CDC guidelines on ways to lessen the risk of infection from Cryptosporidium, Giardia or other microbial pathogens are available from the Safe Drinking Water Hotline (1-800-426-4791).

### *System Improvements*

The Town of Jerusalem – Keuka Park Sewer & Water Department completed phase two of the Keuka Park Water Improvement project.

### *Why Conserve Water?*

There are a number of reasons why it is important to conserve water:

- ◆ Saving water saves energy and some of the costs associated with both of these necessities of life;
- ◆ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ◆ Saving water lessens the strain on the water system during a dry spell or drought; this helps avoid severe water use restrictions and ensures that water is available for essential firefighting needs.

You can play a role in conserving water by becoming conscious of the amount of water your household is using and by looking for ways to use less water whenever you can.

#### Conservation tips include:

- ◆ Load your dishwasher to capacity; automatic dishwashers use 15 gallons for every cycle regardless of how many dishes are loaded.
- ◆ Turn off the tap while brushing your teeth.
- ◆ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons of water a day. Fix the leak and you'll save almost 6,000 gallons of water per year.
- ◆ Check your toilets for leaks by putting a few drops of food coloring in the tank or a leak detection tablet (which can be obtained from the Municipal Office). Watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from a minor toilet water leak, so fixing this problem can save you more than 30,000 gallons of water a year.
- ◆ Use your water meter to detect hidden leaks. Simply turn off all taps and water-using appliances; check the meter after 15 minutes. If it moved, you have a leak.

### *In Conclusion*

Thank you for allowing us to continue to provide you and your family with quality drinking water. We ask that all of our customers help us protect our water sources, which are the heart of our community. Please call our office if you have questions.

**(Prepared March 2023)**