



Do not locate in ditch line or shoulder

Right of Way

Grade

54" Minimum Cover

Foundation Wall

1 2 3 4 5

1. 1/4 Turn Ball Valve
2. Pressure Reducing Valve
3. Meter
4. Double Check Valve
5. 1/4 Turn Ball Valve

Interior water meters must be in heated, dry, accessible space approved by Town.

Water Services over 200 feet in length require a meter pit at the ROW or property line.

Note: All fittings and appurtenances must meet AWWA Standards

KPSW  
Water Service Installation Requirement  
**03/17**